

**Gilbert-Summit Rural Water District
(System #3220001)
2013 Consumer Confidence Report**

**THE WATER WE DRINK
March 20, 2014**

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source consists of eight wells permitted by the South Carolina Department of Health and Environmental Control (SCDHEC). They are located at a specific depth within the Middendorf Aquifer. This aquifer lies in the Coastal Plain of our state.

The 1986 Amendments to the Safe Drinking Water Act established a Wellhead Protection (WHP) Program to serve as a proactive approach to drinking water protection. The WHP Program, being fundamentally proactive, is designed to protect the areas surrounding drinking water wells from contaminants that may be anthropogenic in nature. A Source Water Assessment was completed in April 2003 by SCDHEC. This was done to identify potential contaminant sources (PCS). This revealed 13 PCS. A copy of this assessment is available for your review at <http://www.scdhec.gov/environment/water/srcwetr.htm>. If you do not have internet access, please contact Mark Forrester at (803) 892-5544 to make arrangements to review this document.

If you have any questions about this report or concerning your water utility, please contact Mark Forrester, water district manager, at (803) 892-5544. Information is also available on our website at www.gilbertsummitwater.org. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held

on the fourth Tuesday of every month (except December) at the Gilbert-Summit Rural Water District Office, 136 Hampton Street, Gilbert, SC.

The Gilbert-Summit Rural Water District routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1 to December 31, 2013. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk. In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions, while more information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791:

Non-Detects (ND) – laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level (AL) - The level at which action is taken to mitigate the contaminant.

Highest Detected Level (HDL)

Picocuries per Liter (pCi/l) – picocuries per liter is a measure of the radioactivity in water: one trillionth of a curie or a single penny in \$10,000,000,000.

Maximum Contaminant Level (MCL) - The highest level of contaminant that is allowed in

drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) –The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) –The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Total Trihalomethanes (TTHM): A group of four organic compounds that may form when natural organic matter reacts with chlorine.

CONTAMINANT (UNIT OF MEASURE)	MCLG	MCL	LEVEL DETECTED	VIOLATION YES/NO	TYPICAL SOURCE OF CONTAMINANT	YEAR SAMPLED	
Nitrate (ppm)	10	10	4.3 Range 0 – 4.3	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	2013	
Fluoride (ppm)	4	4	0.94 Range 0 – 0.94	No	Erosion of natural deposits; water additive which promotes strong teeth.	2011	
Barium (ppm)	2	2	0.063 Range 0 – 0.063	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	2011	
Chlorine (ppm)	MRDLG 4	MRDL 4	1.06 Range 0.82- 1.30	No	Water additive used to control microbes	2013	
Copper (ppm)	0	AL 1.3	90 th % = 0.51 1 > AL Range ND – 1.41	No	Corrosion of household plumbing. Erosion of natural deposits	2011	
Lead (ppm)	0	AL 0.015	90 th % = 0.00 0 > AL Range ND – 0.002	No	Corrosion of household plumbing. Erosion of natural deposits	2011	
Combined Radium (pCi/l)	0	5	Site B32003 B32004	6 Range 6 – 7.8	Yes *	Erosion of natural deposits	2013
Alpha emitters (pCi/l)	0	15	Site B32003 B32004	6.89 Range 0 – 6.89	No	Erosion of natural deposits	2013

* Violation Table

Combined Radium 226/228			
Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer			
Violation Type	Violation Begin	Violation End	Violation Explanation
MCL, AVERAGE	01/01/2013	12/02/2013	Water samples showed that the amount of this contaminant in our drinking water at sites B32003 & B32004 were above its standard (called a maximum contaminant level – MCL) for the period indicated.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Gilbert-Summit Rural Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

The table shows that our system continues to deal with a radium issue this year. We received a violation for the annual running average for Combined Radium levels at two of our wells which exceeded the MCL. This is not an immediate risk. This is a naturally occurring radioactive material found in soil, water, rocks, plants and foods. This higher level was measured at **two** of our eight wells. All of our water is mixed or blended; therefore this level of radium is not representative of what is actually supplied to our customers. The district has tested water at several places in our system and none were in excess of the MCL. However, some people who drink water containing radium 226 and radium 228 in excess of the MCL over many years may have an increased risk of getting cancer. How does this level of risk compare to other risks in life? It is approximately the same as the risk of dying from lightning strikes, or tornadoes or hurricanes. Fortunately, the radium level can be controlled by various processes or by removing the particular source from the water system.

The Water District has worked with SCDHEC investigating all possible options to remedy this situation. Filtration appears to be the best solution

for our water system, so the District has installed filter systems on the offending wells. This was recently completed, and as of December 2, 2013 no water above the MCL was being pumped into our water system.

We have also learned, through our monitoring and testing, that some other contaminants have been detected. The EPA has, however, determined that your water is safe at these levels. MCL's are set at very stringent levels. To understand the possible effects described for many regulated constituents, a person would have to drink 2 quarts of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for your understanding.

Should you have any further questions, please contact our office at (803) 892-5544 or visit our website www.gilbertsummitwater.org.




Gilbert-Summit Rural Water District

P O Box 172
Gilbert, South Carolina 29054

RETURN SERVICE REQUESTED

PRESORTED
FIRST CLASS MAIL
U.S. POSTAGE
PAID
LEESVILLE, SC 29070
Permit #3



2013
Consumer Confidence
Report

(803) 892-5544
P.O. BOX 172
GILBERT, SC 29054