

**Gilbert-Summit Rural Water District**  
 (System #3220001)  
 2021 Water Quality Report

**THE WATER WE DRINK**  
 March 25, 2022

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies

**Where does my water come from?**

Our water source is groundwater and comes from seven wells permitted by the South Carolina Department of Health and Environmental Control (SCDHEC). They are located at a specific depth within the Middendorf Aquifer. This aquifer lies in the Coastal Plain of our state. A Source Water Assessment was completed in June 2006 by SCDHEC. This was done to identify potential contaminant sources (PCS). This revealed 13 PCS. A copy of this assessment is available for your review on our website at <https://www.gilbertsummitwater.org/customer-service/source-water-assessment/>. If you do not have internet access, please contact Mark Forrester at (803) 892-5544 to make arrangements to review this document.

**Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to

lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

**Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Gilbert-Summit Rural Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**How can I get involved?**

If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Tuesday of every month (except December) at the Gilbert-Summit Rural Water District Office, 136 Hampton Street, Gilbert, SC 29054.

The following table shows the results of our monitoring for the period of January 1 to December 31, 2021.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (ppm)	4	4	1.05	.05	1.71	2021	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	2	1.27	2.78	2020	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	2	1.79	1.84	2021	No	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>								
Barium (ppm)	2	2	0.16	0	0.16	2017	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	1.1	0	1.1	2017	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	5.0	0	5.1	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (ppm)	NA	NA	23	4.1	23	2017	No	Erosion of natural deposits
<b>Radioactive Contaminants</b>								
Radium (combined 226/228) (pCi/L)	0	5	4.0	0	4.92	2021	No	Erosion of natural deposits
Uranium (µg/L)	0	30	4.8	0	4.8	2016	No	Erosion of natural deposits
Gross Alpha (pCi/L)	0	15	8	0	8.05	2021	No	Erosion of natural deposits

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
<b>Inorganic Contaminants</b>							
Copper - action level at consumer taps (ppm)	1.3	1.3	0.833	2019	2	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	4	2019	0	No	Corrosion of household plumbing systems; Erosion of natural deposits

Coliform Bacteria						
MCLG	Total Coliform MCL	Highest No. of Positive	Fecal Coliform or E. Coli MCL	Total No. of Positive E.Coli or Fecal Coli Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample	1		0	N	Naturally present in the environment

### Important Drinking Water Definitions

#### Unit Descriptions

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.


If you have any questions about this report or concerning your water utility, please contact Mark Forrester, Water District Manager, at (803) 892-5544. Information is also available on our website at [www.gilbertsummitwater.org](http://www.gilbertsummitwater.org). We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Tuesday of every month (except December) at the Gilbert-Summit Rural Water District Office, 136 Hampton Street, Gilbert, SC, 29054.

PRESORTED  
 FIRST CLASS MAIL  
 U.S. POSTAGE  
**PAID**  
 LEESVILLE, SC 29070  
 Permit #3


**Gilbert-Summit Rural Water District**

P O Box 172  
 Gilbert, South Carolina 29054

RETURN SERVICE REQUESTED



2021  
 Water Quality  
 Report

(803) 892-5544  
 P.O. Box 172  
 GILBERT, SC 29054